



**Biosolids Facility**

Wastewater Sludge Pumped to Biosolids Facility

**Proposed Saanich East Attenuation Tanks**  
Wet Weather Overflow Slowly Released Into East Coast Interceptor

McLoughlin Point Wastewater Treatment Plant

Macaulay Point Pump Station

Wet Weather Outfall: Screened Effluent During Extreme Wet Weather (flow more than 4x average dry weather flow)

Wastewater Pumped to McLoughlin Point (up to 3x average dry weather flow)

Clover Point Pump Station

Wet Weather Outfall: Screened Effluent During Extreme Wet Weather (flow more than 3x average dry weather flow)

Effluent Outfall

# CORE AREA WASTEWATER TREATMENT PROGRAM

## McLoughlin Point Option



0 0.5 1 2 Kilometres  
Projection: UTM ZONE 10N NAD 83

- PS Pump Station
- TP Treatment Plant
- Proposed Route
- Select Sewer Trunks
- Existing Outfalls

Important: This map is for general information purposes only. The Capital Regional District (CRD) makes no representations or warranties regarding the accuracy or completeness of this map or the suitability of the map for any purpose. This map is not for navigation. The CRD will not be liable for any damage, loss or injury resulting from the use of the map or information on the map and the map may be changed by the CRD at any time.