

CORE AREA WASTEWATER TREATMENT PROGRAM

McLoughlin Point Option



- PS** Pump Station
- TP** Treatment Plant
- Proposed Route
- Select Sewer Trunks
- Existing Outfalls

Biosolids Facility

Wastewater Sludge Pumped to Biosolids Facility

Proposed Saanich East Attenuation Tanks
Wet Weather Overflow Slowly Released Into East Coast Interceptor

McLoughlin Point Wastewater Treatment Plant

Macauly Point Pump Station

Wastewater Pumped to McLoughlin Point (up to 3x average dry weather flow)

Clover Point Pump Station

Wet Weather Outfall:
Primary Treated Effluent During Extreme Wet Weather (flow more than 4x average dry weather flow)

Wet Weather Outfall:
Primary Treated Effluent During Extreme Wet Weather (flow more than 3x average dry weather flow)

Effluent Outfall



Projection: UTM ZONE 10N NAD 83

Disclaimer
This map is for general information purposes only and may contain inaccuracies.

